

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1574:105 Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Fairfield, NJ 07004-1561  
Contact: \*Ron Dalton (310) 725-2972 Fax (310) 725-2942

**DESIGN:** Models ADT-HFS and ADT-HRS heat detectors. Model ADT-HFS is a 135°F fixed temperature detector and Model ADT-HRS is a 135°F fixed temperature and a 15°F/min rate of rise detector. Refer to listee's data sheet for detailed model descriptions and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as heat detector for use with listee's separately listed compatible bases and fire alarm control units.

**XLF:** 7270-1591:125 Formerly 7270-1388:185

\*Rev. 07-01-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 1, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager